

Problem:

Water backing into the house.
Alarm is **NOT** going off.
OR **NO** Alarm Present

No Alarm is Present:

This means you have a gravity system. Check baffles and pipes between compartments/tanks.

Is the baffle or pipes plugged?

Yes:

Clean out blockage as needed.

NO:

Then the line from the house to the 1st tank is plugged.

OR

Drain field may be over loaded or frozen. (Depending on season.)

Call Steinbrecher Companies
763-274-0925

YES power is on:
There is a possible plugged line or baffle

Test Alarm to confirm it works properly.

Yes:

Alarm works Properly.

Check baffles and pipes between compartments/tanks.

Is the baffle or pipes plugged?

Yes:

Clean out blockage as needed.

NO:

Then the line from the house to the 1st tank is plugged.

Call Steinbrecher Companies
763-274-0925

Alarm Present but not going off.

Confirm pump and alarm have power, and power is on.

NO power to alarm:
Turn power on.

Alarm goes off:

If alarm does not shut off in 5 minutes please see **Problem: Alarm is going off.**

If breakers trip immediately again, you have a short in the system somewhere.

Call Steinbrecher Companies
763-274-0925

Warning: All septic systems are installed differently. You need to take extreme caution when working with electricity. Please call a professional if you have any questions or if you are uncomfortable performing any of these tasks.